

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1157:112 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Digital Monitoring Products, 2841 E. Industrial Dr., Springfield MO 65802
Contact: *Terry Shelton (417) 831-9362 Fax (417) 831-1325

DESIGN: Models 850D (key lock, push bar) and 850S (key lock, no push bar) noncoded manual pull stations. Suitable for outdoor use when installed with Model 850-WP back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

XLF: 7150-1408:107

*Rev. 06-07-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 7, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager